IN THE COURT OF THE DISTRICT JUDGE, BANGALORE.

Miscellaneous No. 123 *of* 1932-33.

In the matter of the Mysore Companies Regulation No. 8 of 1917 and of the Mysore Pharmaceuticals, Limited, Bangalore.

Notice is hereby given that a Petition for the winding up of the abovenamed Company by the Court, was on the 20th day of February 1933 presented to the Court of the District Judge, Bangalore by Mr. T. Ramachandra Rao, Mylapore, Madras, a Creditor of the said Company, and that it has been directed that the said Petition shall be heard before the said Court on the 10th day of July 1933; and any creditor or contributory of the said Company desirous to oppose the making of an order for the winding up of the said Company under the above Regulation, should appear at the time of hearing, by himself or his Advocate or Pleader for that purpose; and a copy of the Petition will be furnished to any Creditor or Contributory of the said Company requiring the same, on application to the said Court and on payment of the charges for the same.

A. R. NAGESVARA IYER,
Advocate for the Petitioner.

MYSORE GOVERNMENT STATIONERY DEPOT.

Abstract Notification, dated 6th June 1933.

The attention of the public is invited to the detailed Notification dated 10th May 1933, calling for sealed tenders for the supply of Carting and Miscellaneous articles required for the use of the Government Stationery Depot, Bangalore for the official year 1933-34, published in pages 562 and 563 of Part VI of the *Mysore Gazette*, dated 18th May 1933.

The last date for receiving the Tenders in the Stationery Depot is Monday, the 12th June 1933.

B. SRINIVASA IYENGAR,
Ag. *Superintendent of Stationery,*
Bangalore.

OFFICE OF THE SECRETARY, STORES PURCHASE COMMITTEE BANGALORE.

No. S. P. C. 20730-44, *dated 19th May* 1933.

To

The Firms Dealing in Electrical Equipments

Enquiry No. 355.

Oil Circuit Breakers.

Gentlemen,

Please intimate your best prices and earliest time of delivery for the following electrical equipment:—

Three Oil Circuit Breakers, 15,000 volts, 1,500 amps. capacity, 25 cycles, interrupting rating not less than 350,000 Kva. at rated voltage. The switch should be motor-operated and should be suitable for installing in the existing cells as shown in the blue print available in the office of the undersigned. The size of the switch should be such as to go into these cells without any alteration, as it is not possible to provide additional space for their installation. The motor operating the switch should be suitable for 90 to 140 volts D. C. and the control of this switch from the switch-board should be suitable for 90 to 140 volts D. C.

The price to be quoted should be for delivery c.i.f., Madras.

This enquiry will close on the 15*th July* 1933.

Yours faithfully,
M. S. RAMCHENDRA RAO,
Secretary,
Stores Purchase Committee.